



# City of Zimmerman

12980 Fremont Avenue  
Zimmerman, MN 55398

Telephone 763-856-4666 \* Fax 763-856-4787  
[www.zimmerman.govoffice.com](http://www.zimmerman.govoffice.com)

---

## TO ALL UNDERGROUND CONTRACTORS

As of January 1, 2013 all water lines will be air tested throughout the year at 100 PSI for 15 minutes from the time the inspector arrives.

The water line will run parallel to the sewer line with a 2-foot separation between the services.

The water line will be at a minimum depth of 6 feet.

The two services will enter the building under the footing with a clearance of no less than 6 inches from the footing in any direction.

Sewer connection for single family

Schedule 40 – 4 inch PVC

Clean out 2 feet outside exterior wall – cap the clean out – no 90-degree elbows

Water connection for single family

1" copper K

No splices will be allowed

Brick under curb box and verify standpipes will be straight

Contractor will provide sketch of utility placement of elbows and lengths of pipe